

5.3.12 Main Commercial Heating and Cooling Equipment as of 1995, 1999, and 2003 (Percent of Total Floorspace) (1)

Heating Equipment	1995	1999	2003 (2)	Cooling Equipment	1995	1999	2003 (2)
Packaged Heating Units	29%	38%	28%	Packaged Air Conditioning Units	45%	54%	46%
Boilers	29%	29%	32%	Individual Air Conditioners	21%	21%	19%
Individual Space Heaters	29%	26%	19%	Central Chillers	19%	19%	18%
Furnaces	25%	21%	30%	Residential Central Air Conditioners	16%	12%	17%
Heat Pumps	10%	13%	14%	Heat Pumps	12%	14%	14%
District Heat	10%	8%	8%	District Chilled Water	4%	4%	4%
Other	11%	6%	5%	Swamp Coolers	4%	3%	2%
				Other	2%	2%	2%

Note(s): 1) Heating and cooling equipment percentages of floorspace total more than 100% since equipment shares floorspace. 2) Malls are no longer included in most CBECs tables; therefore, some data is not directly comparable to past CBECs.

Source(s): EIA, Commercial Building Characteristics 1995, Oct. 1998, Tables B34 and B36 for 1995, and EIA, Commercial Building Characteristics 1999, Aug. 2002, Tables B33 and B34 for 1999; and, EIA, 2003 Commercial Buildings Energy Consumption and Expenditures: Consumption and Expenditures Tables, June 2006, Tables B39 and B41 for 2003.